



**OFFICE OF THE DEPUTY FIRE OFFICER,
CUTTACK CIRCLE,
BUXI BAZAR, CUTTACK, 753001.**

FORM-V

FIRE SAFETY CERTIFICATE

(See rule-13(3) of the Odisha Fire Prevention and Fire Safety Rules, 2017 r/w Odisha Fire Prevention and Fire Safety (Amendment) Rules, 2019.)

File No. X-2-B-50-2020

Certificate No. 16 /CR.CTC,

dated: 24.02.2021

This Certificate is valid up to 23.02.2023.

(Apply for renewal at least three months before expiry)

Certified that the Sri Sathya Sai Jnana Vikash School (G+1 floor), over plot no.657, 631, 664, Khata no.969 & 1029/324, At/Po-Pankapal, Via-Rahama, Dist-Jagatsinghpur consisting of total 01 no. building was inspected by Officers of the Fire Service on 24.02.2021 in presence of Sri Gagan Bihari Prusty, President with team and it has been found to comply with the Fire prevention and safety requirements in accordance with the Odisha Fire Prevention and Fire Safety Rules-2017 read with Fire Prevention and Fire Safety (Amendment) Rules-2019 and Odisha Fire Service one time relaxation scheme published vide Govt. of Odisha Home Department Notification No.28550/CD, Bhubaneswar, dt.28.08.2020 and that its various floors are fit for occupancy or usage as noted hereunder against each subject to compliance to the conditions as prescribed herein below:

01	Ground and 1 st floor	---Usage---	Educational (School)
----	----------------------------------	-------------	-------------------------

CONDITIONS:

1. Fire prevention and safety measures and appliances, availability of water supplies and means of access thereto etc provided in the building or premises, should be maintained by the occupier(s) in best repairs and efficient working condition at all times for use by the occupants or the members of the Fire Service or both in the event of outbreak of fire.
2. The setbacks, driveways, entrance gates, exits, corridors and escape ways should not be changed, obstructed or modified in any way.
3. The occupiers(s) shall train all staff and occupants periodically to make them well conversant in use and operation of the fire prevention and safety measures.
4. Fire drills/rehearsals should be organised at least once in six months by involving local Fire Station.
5. Photocopies of this Certificate should be framed and displayed at all conspicuous places in all lobbies/corridors in all floors of building/premises.
6. The plan needs to be regularized / approved by the competent plan approving authority of the jurisdiction as per Govt. Of Odisha Home Department notification No.28550/CD, Bhubaneswar, dt.28.08.2020 regarding one time relaxation scheme for Odisha Fire Service on requirement of structural Fire Safety parameters.
7. All other conditions furnished in Odisha Fire Service one time relaxation scheme published vide Govt. of Odisha Home Department Notification No.28550/CD, Bhubaneswar, dt.28.08.2020 will be applicable to this occupancy and applicant will comply on each point accordingly.
8. This fire safety Certificate do not absolve provisions made in any other rules and will not automatically immune the provisions made therein.

By order of the Director of Fire Service


 24.02.2021

(Trilok Kumar Babu)
Deputy Fire Officer,
Cuttack Circle, Cuttack

Name & Designation of the Issuing Officer:- Trilok Kumar Babu, Deputy Fire Officer

Memo No- 375 /CR.CTC.

Date-24/02/2021

Copy to the President, Sri Sathya Sai Jnanavikash School, At/Po-Pankapal, Ps-Kujanga, Dist-Jagatsinghpur for information and necessary action from your end.



Deputy Fire Officer,
Cuttack Circle, Cuttack.

Rashmi
ta Kabi

Digitally signed
by Rashmita Kabi
Date: 2026.09.11
11:48:14 +05'30'



SWADHIN FIRE SERVICE

B.O.:Korkor, Begunia, Jagatsinghpur – 754136
H.O. : New LIC Colony, Link Road, Cuttack – 753009
GSTIN - 21BSFPN5676M1ZA Mob - 82498971714



Ref..JSP/A2/429...

Date..28.06.26.

TO WHOM IT MAY CONCERN

Client Name: Sri Sathya Sai Jnana Vikash School, Pankapal

This is to certify that the following 11 Nos. ABC Type fire extinguisher and 2 Nos. CO2 Type Fire Extinguisher supply on Dt. 28.06.2026 in good and perfect working condition. This Fitness valid up to 27.06.2027.

S.L No.	SYLS. No.	Type	Capacity	Qnty.	Remarks
1.	As on Body	ABC Type	06 K.g	11 Nos.	Ok
2.	As on Body	CO2 Type	4.5 K.g	2 Nos.	Ok

Rashmi
ta Kabi

Digitally signed
by Rashmita Kabi
Date: 2026.09.11
11:48:51 +05'30'



For Swadhin Fire Service